



Phoenix Safe Company
Apex House
1 Orrell Mount
Liverpool
L20 6NS

This certificate confirms that Phoenix Firefighter II is designed and tested to the NT Fire 017-90 Paper (FS0441K/E/F & FS0442K/E/F) and NT Fire 017-120 Paper (FS0443K/E/F) standard providing up to 2 hours fire protection for paper.

This series is also tested to MCT-DIP120-60DM fire test standard, providing 60 minutes fire protection for digital media, DVD's, USB's and memory sticks.

The Phoenix Firefighter II Series is also fire and impact tested from 9.1 metres.

Fire Protection for paper (FS0441K/E/F & FS0442K/E/F)	90 minutes
Fire Protection for paper (FS0443K/E/F)	120 minutes
Fire Protection for digital media (FS0440K/E/F)	60 minutes
Drop Test	9.1 metres

Phoenix Firefighter II FS0440E Series

NT Fire 017-90 Paper
NT Fire 017-120 Paper
MCT-DIP-60DM

Certificate No 16 49 02
Certificate No 16 49 03
Certificate No D101030

Daniel P Thompson.....Managing Director